

January 08, 2024

John Cable
Triangle
17855 Elk Prairie Drive
P.O. Box 1026
Rolla, MO 65402
TEL: (573) 364-1864
FAX: (573) 364-4782



Illinois	100226
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

RE: RPS- Mark Twain Elementary

WorkOrder: 23121749

Dear John Cable:

TEKLAB, INC received 51 samples on 12/21/2023 1:00:00 PM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Marvin L. Darling
Project Manager
(618)344-1004 ex 41
mdarling@teklabinc.com



Report Contents

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23121749

Client Project: RPS- Mark Twain Elementary

Report Date: 08-Jan-24

This reporting package includes the following:

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Quality Control Results	9
Receiving Check List	12
Chain of Custody	Appended

Client: Triangle

Work Order: 23121749

Client Project: RPS- Mark Twain Elementary

Report Date: 08-Jan-24

Abbr Definition

* Analytes on report marked with an asterisk are not NELAP accredited

CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.

CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.

DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.

DNI Did not ignite

DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.

ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.

IDPH IL Dept. of Public Health

LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.

LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.

MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."

MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).

MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MW Molecular weight

NC Data is not acceptable for compliance purposes

ND Not Detected at the Reporting Limit

NELAP NELAP Accredited

PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.

RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.

RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).

SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.

Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.

TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"

TNTC Too numerous to count (> 200 CFU)

Client: Triangle

Work Order: 23121749

Client Project: RPS- Mark Twain Elementary

Report Date: 08-Jan-24

Qualifiers

- # - Unknown hydrocarbon
- C - RL shown is a Client Requested Quantitation Limit
- H - Holding times exceeded
- J - Analyte detected below quantitation limits
- ND - Not Detected at the Reporting Limit
- S - Spike Recovery outside recovery limits
- X - Value exceeds Maximum Contaminant Level
- B - Analyte detected in associated Method Blank
- E - Value above quantitation range
- I - Associated internal standard was outside method criteria
- M - Manual Integration used to determine area response
- R - RPD outside accepted recovery limits
- T - TIC(Tentatively identified compound)



Case Narrative

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23121749

Client Project: RPS- Mark Twain Elementary

Report Date: 08-Jan-24

Cooler Receipt Temp: NA °C

Locations

Collinsville

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email jhriley@teklabinc.com

Collinsville Air

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email EHurley@teklabinc.com

Springfield

Address 3920 Pintail Dr
Springfield, IL 62711-9415
Phone (217) 698-1004
Fax (217) 698-1005
Email KKlostermann@teklabinc.com

Chicago

Address 1319 Butterfield Rd.
Downers Grove, IL 60515
Phone (630) 324-6855
Fax
Email arenner@teklabinc.com

Kansas City

Address 8421 Nieman Road
Lenexa, KS 66214
Phone (913) 541-1998
Fax (913) 541-1998
Email jhriley@teklabinc.com



Accreditations

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23121749

Client Project: RPS- Mark Twain Elementary

Report Date: 08-Jan-24

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2025	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2024	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2024	Collinsville
Missouri	MDNR	00930		5/31/2023	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



Laboratory Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23121749

Client Project: RPS- Mark Twain Elementary

Report Date: 08-Jan-24

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)									
Lead									
23121749-001A	26-B	NELAP		0.0010	< 0.0010	mg/L	1	01/03/2024 10:17	12/20/2023 10:00
23121749-002A	27-A	NELAP		0.0010	0.0012	mg/L	1	01/03/2024 9:28	12/20/2023 10:00
23121749-003A	27-B	NELAP		0.0010	< 0.0010	mg/L	1	01/03/2024 9:32	12/20/2023 10:00
23121749-004A	28-A	NELAP		0.0010	0.0026	mg/L	1	01/03/2024 9:52	12/20/2023 10:00
23121749-005A	28-B	NELAP		0.0010	< 0.0010	mg/L	1	01/03/2024 9:36	12/20/2023 10:00
23121749-006A	29-A	NELAP		0.0010	< 0.0010	mg/L	1	01/03/2024 9:40	12/20/2023 10:00
23121749-007A	29-B	NELAP		0.0010	< 0.0010	mg/L	1	01/03/2024 9:44	12/20/2023 10:00
23121749-008A	30-A	NELAP		0.0010	< 0.0010	mg/L	1	01/03/2024 9:48	12/20/2023 10:00
23121749-009A	30-B	NELAP		0.0010	< 0.0010	mg/L	1	12/29/2023 14:27	12/20/2023 10:00
23121749-010A	31-A	NELAP		0.0010	< 0.0010	mg/L	1	12/29/2023 14:31	12/20/2023 10:00
23121749-011A	31-B	NELAP		0.0010	< 0.0010	mg/L	1	12/29/2023 14:35	12/20/2023 10:00
23121749-012A	32-A	NELAP		0.0010	0.0020	mg/L	1	01/02/2024 11:52	12/20/2023 10:00
23121749-013A	32-B	NELAP		0.0010	< 0.0010	mg/L	1	01/02/2024 12:06	12/20/2023 10:00
23121749-014A	33-A	NELAP		0.0010	< 0.0010	mg/L	1	01/02/2024 12:10	12/20/2023 10:00
23121749-015A	33-B	NELAP		0.0010	< 0.0010	mg/L	1	01/02/2024 12:14	12/20/2023 10:00
23121749-016A	34-A	NELAP		0.0010	< 0.0010	mg/L	1	01/02/2024 12:25	12/20/2023 10:00
23121749-017A	34-B	NELAP		0.0010	< 0.0010	mg/L	1	01/02/2024 12:28	12/20/2023 10:00
23121749-018A	35-A	NELAP		0.0010	< 0.0010	mg/L	1	01/02/2024 12:32	12/20/2023 10:00
23121749-019A	35-B	NELAP		0.0010	< 0.0010	mg/L	1	01/02/2024 12:36	12/20/2023 10:00
23121749-020A	36-A	NELAP		0.0010	0.0022	mg/L	1	01/02/2024 12:39	12/20/2023 10:00
23121749-021A	36-B	NELAP		0.0010	< 0.0010	mg/L	1	01/02/2024 12:54	12/20/2023 10:00
23121749-022A	39-A	NELAP		0.0010	< 0.0010	mg/L	1	01/02/2024 12:58	12/20/2023 10:00
23121749-023A	39-B	NELAP		0.0010	< 0.0010	mg/L	1	01/02/2024 13:01	12/20/2023 10:00
23121749-024A	40-A	NELAP		0.0010	0.0021	mg/L	1	01/02/2024 13:05	12/20/2023 10:00
23121749-025A	40-B	NELAP		0.0010	< 0.0010	mg/L	1	01/02/2024 13:09	12/20/2023 10:00
23121749-026A	41-A	NELAP		0.0010	0.0033	mg/L	1	01/02/2024 13:20	12/20/2023 10:00
23121749-027A	41-B	NELAP		0.0010	< 0.0010	mg/L	1	01/02/2024 13:23	12/20/2023 10:00
23121749-028A	42-A	NELAP		0.0010	< 0.0010	mg/L	1	12/29/2023 17:03	12/20/2023 10:00
23121749-029A	42-B	NELAP		0.0010	< 0.0010	mg/L	1	12/29/2023 12:28	12/20/2023 10:00
23121749-030A	44-A	NELAP		0.0010	< 0.0010	mg/L	1	12/29/2023 12:32	12/20/2023 10:00
23121749-031A	44-B	NELAP		0.0010	< 0.0010	mg/L	1	12/29/2023 12:36	12/20/2023 10:00
23121749-032A	45-A	NELAP		0.0010	0.0020	mg/L	1	12/29/2023 12:40	12/20/2023 10:00
23121749-033A	45-B	NELAP		0.0010	< 0.0010	mg/L	1	12/29/2023 12:44	12/20/2023 10:00
23121749-034A	46-A	NELAP		0.0010	0.0073	mg/L	1	12/29/2023 12:48	12/20/2023 10:00
23121749-035A	46-B	NELAP		0.0010	< 0.0010	mg/L	1	01/02/2024 11:48	12/20/2023 10:00
23121749-036A	47-A	NELAP		0.0010	< 0.0010	mg/L	1	12/29/2023 13:17	12/20/2023 10:00
23121749-037A	47-B	NELAP		0.0010	< 0.0010	mg/L	1	12/29/2023 13:46	12/20/2023 10:00
23121749-038A	48-A	NELAP		0.0010	< 0.0010	mg/L	1	12/29/2023 13:21	12/20/2023 10:00
23121749-039A	48-B	NELAP		0.0010	< 0.0010	mg/L	1	12/29/2023 13:25	12/20/2023 10:00
23121749-040A	49-A	NELAP		0.0010	0.0042	mg/L	1	12/29/2023 13:29	12/20/2023 10:00
23121749-041A	49-B	NELAP		0.0010	< 0.0010	mg/L	1	12/29/2023 13:34	12/20/2023 10:00
23121749-042A	50-A	NELAP		0.0010	< 0.0010	mg/L	1	12/29/2023 13:38	12/20/2023 10:00
23121749-043A	50-B	NELAP		0.0010	< 0.0010	mg/L	1	12/29/2023 13:42	12/20/2023 10:00
23121749-044A	51-A	NELAP		0.0010	< 0.0010	mg/L	1	12/29/2023 14:39	12/20/2023 10:00
23121749-045A	51-B	NELAP		0.0010	< 0.0010	mg/L	1	12/29/2023 14:10	12/20/2023 10:00
23121749-046A	52-A	NELAP		0.0010	0.0016	mg/L	1	12/29/2023 14:15	12/20/2023 10:00
23121749-047A	52-B	NELAP		0.0010	0.0011	mg/L	1	12/29/2023 14:19	12/20/2023 10:00
23121749-048A	53-A	NELAP		0.0010	< 0.0010	mg/L	1	12/29/2023 14:23	12/20/2023 10:00



Laboratory Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23121749

Client Project: RPS- Mark Twain Elementary

Report Date: 08-Jan-24

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)									
Lead									
23121749-049A	53-B	NELAP	0.0010	0.0010	< 0.0010	mg/L	1	01/02/2024 15:46	12/20/2023 10:00
23121749-050A	54-A	NELAP	0.0010	0.0010	0.0017	mg/L	1	01/02/2024 15:50	12/20/2023 10:00
23121749-051A	54-B	NELAP	0.0010	0.0010	< 0.0010	mg/L	1	01/02/2024 16:04	12/20/2023 10:00



Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23121749

Client Project: RPS- Mark Twain Elementary

Report Date: 08-Jan-24

EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch 216496		SampType: MBLK		Units mg/L						
SampID: MBLK-216496										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/03/2024

Batch 216496		SampType: LCS		Units mg/L						
SampID: LCS-216496										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		0.0497	0.0500	0	99.4	85	115	01/03/2024

Batch 216496		SampType: MS		Units mg/L						
SampID: 23121749-004AMS										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010	E	0.100	0.1000	0.002627	97.6	70	130	01/03/2024

Batch 216496		SampType: MSD		Units mg/L						
SampID: 23121749-004AMSD										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed
Lead		0.0010	E	0.113	0.1000	0.002627	110.8	0.1002	12.39	01/03/2024

Batch 216496		SampType: MS		Units mg/L						
SampID: 23121857-032AMS										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		0.0973	0.1000	0.001271	96.0	70	130	01/03/2024

Batch 216496		SampType: MSD		Units mg/L						
SampID: 23121857-032AMSD										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed
Lead		0.0010		0.0979	0.1000	0.001271	96.6	0.09728	0.65	01/03/2024

Batch 216497		SampType: MBLK		Units mg/L						
SampID: MBLK-216497										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	12/29/2023

Batch 216497		SampType: LCS		Units mg/L						
SampID: LCS-216497										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		0.0474	0.0500	0	94.9	85	115	12/29/2023



Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23121749

Client Project: RPS- Mark Twain Elementary

Report Date: 08-Jan-24

EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch 216497		SampType: MS		Units mg/L						
SampID: 23121749-015AMS										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		0.0986	0.1000	0	98.6	70	130	01/02/2024

Batch 216497		SampType: MSD		Units mg/L						
SampID: 23121749-015AMSD										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed
Lead		0.0010	E	0.100	0.1000	0	100.3	0.09860	1.67	01/02/2024

Batch 216497		SampType: MS		Units mg/L						
SampID: 23121749-025AMS										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		0.0990	0.1000	0.0005960	98.4	70	130	01/02/2024

Batch 216497		SampType: MSD		Units mg/L						
SampID: 23121749-025AMSD										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed
Lead		0.0010	E	0.101	0.1000	0.0005960	100.7	0.09902	2.27	01/02/2024

Batch 216509		SampType: MBLK		Units mg/L						
SampID: MBLK-216509										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	12/29/2023

Batch 216509		SampType: LCS		Units mg/L						
SampID: LCS-216509										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		0.0474	0.0500	0	94.9	85	115	12/29/2023

Batch 216509		SampType: MS		Units mg/L						
SampID: 23121749-037AMS										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		0.0882	0.1000	0	88.2	70	130	12/29/2023

Batch 216509		SampType: MSD		Units mg/L						
SampID: 23121749-037AMSD										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed
Lead		0.0010		0.0897	0.1000	0	89.7	0.08822	1.71	12/29/2023



Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23121749

Client Project: RPS- Mark Twain Elementary

Report Date: 08-Jan-24

EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch 216509		SampType: MS		Units mg/L							Date Analyzed
SampID: 23121749-044AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.0894	0.1000	0.0009500	88.5	70	130	12/29/2023	

Batch 216509		SampType: MSD		Units mg/L							RPD Limit: 20	Date Analyzed
SampID: 23121749-044AMSD												
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed		
Lead		0.0010		0.0892	0.1000	0.0009500	88.3	0.08944	0.25	12/29/2023		

Batch 216510		SampType: MBLK		Units mg/L							Date Analyzed
SampID: MBLK-216510											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/02/2024	

Batch 216510		SampType: LCS		Units mg/L							Date Analyzed
SampID: LCS-216510											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.0513	0.0500	0	102.7	85	115	01/02/2024	

Batch 216510		SampType: MS		Units mg/L							Date Analyzed
SampID: 23121695-009AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.0950	0.1000	0	95.0	70	130	01/02/2024	

Batch 216510		SampType: MSD		Units mg/L							RPD Limit: 20	Date Analyzed
SampID: 23121695-009AMSD												
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed		
Lead		0.0010		0.0990	0.1000	0	99.0	0.09496	4.18	01/02/2024		

Batch 216510		SampType: MS		Units mg/L							Date Analyzed
SampID: 23121695-013AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.0972	0.1000	0.0005390	96.6	70	130	01/02/2024	

Batch 216510		SampType: MSD		Units mg/L							RPD Limit: 20	Date Analyzed
SampID: 23121695-013AMSD												
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed		
Lead		0.0010		0.0985	0.1000	0.0005390	97.9	0.09717	1.33	01/02/2024		



Receiving Check List

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23121749

Client Project: RPS- Mark Twain Elementary

Report Date: 08-Jan-24

Carrier: John Cable

Received By: HAW

Completed by:

Reviewed by:

On:

21-Dec-23

Hannah Walker

On:

21-Dec-23

Ellie Hopkins

Pages to follow: Chain of custody

Extra pages included

- Shipping container/cooler in good condition? Yes No Not Present Temp °C **NA**
- Type of thermal preservation? None Ice Blue Ice Dry Ice
- Chain of custody present? Yes No
- Chain of custody signed when relinquished and received? Yes No
- Chain of custody agrees with sample labels? Yes No
- Samples in proper container/bottle? Yes No
- Sample containers intact? Yes No
- Sufficient sample volume for indicated test? Yes No
- All samples received within holding time? Yes No
- Reported field parameters measured: Field Lab NA
- Container/Temp Blank temperature in compliance? Yes No

When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.

- Water – at least one vial per sample has zero headspace? Yes No No VOA vials
- Water - TOX containers have zero headspace? Yes No No TOX containers
- Water - pH acceptable upon receipt? Yes No NA
- NPDES/CWA TCN interferences checked/treated in the field? Yes No NA

Any No responses must be detailed below or on the COC.

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory.

1-A	DRINKING WATER	LEAD	12/20/23 @ 1000
1-B	DRINKING WATER	LEAD	12/20/23 @ 1000
2-A	DRINKING WATER	LEAD	12/20/23 @ 1000
2-B	DRINKING WATER	LEAD	12/20/23 @ 1000
3-A	DRINKING WATER	LEAD	12/20/23 @ 1000
3-B	DRINKING WATER	LEAD	12/20/23 @ 1000
4-A	DRINKING WATER	LEAD	12/20/23 @ 1000
4-B	DRINKING WATER	LEAD	12/20/23 @ 1000
5-A	DRINKING WATER	LEAD	12/20/23 @ 1000
5-B	DRINKING WATER	LEAD	12/20/23 @ 1000
6-A	DRINKING WATER	LEAD	12/20/23 @ 1000
6-B	DRINKING WATER	LEAD	12/20/23 @ 1000
7-A	DRINKING WATER	LEAD	12/20/23 @ 1000
7-B	DRINKING WATER	LEAD	12/20/23 @ 1000
8-A	DRINKING WATER	LEAD	12/20/23 @ 1000
8-B	DRINKING WATER	LEAD	12/20/23 @ 1000
9-A	DRINKING WATER	LEAD	12/20/23 @ 1000
9-B	DRINKING WATER	LEAD	12/20/23 @ 1000
10-A	DRINKING WATER	LEAD	12/20/23 @ 1000
10-B	DRINKING WATER	LEAD	12/20/23 @ 1000
11-A	DRINKING WATER	LEAD	12/20/23 @ 1000
11-B	DRINKING WATER	LEAD	12/20/23 @ 1000
12-A	DRINKING WATER	LEAD	12/20/23 @ 1000
12-B	DRINKING WATER	LEAD	12/20/23 @ 1000
13-A	DRINKING WATER	LEAD	12/20/23 @ 1000
13-B	DRINKING WATER	LEAD	12/20/23 @ 1000
14-A	DRINKING WATER	LEAD	12/20/23 @ 1000
14-B	DRINKING WATER	LEAD	12/20/23 @ 1000
15-A	DRINKING WATER	LEAD	12/20/23 @ 1000
15-B	DRINKING WATER	LEAD	12/20/23 @ 1000
16-A	DRINKING WATER	LEAD	12/20/23 @ 1000
16-B	DRINKING WATER	LEAD	12/20/23 @ 1000
17-A	DRINKING WATER	LEAD	12/20/23 @ 1000
17-B	DRINKING WATER	LEAD	12/20/23 @ 1000
18-A	DRINKING WATER	LEAD	12/20/23 @ 1000
18-B	DRINKING WATER	LEAD	12/20/23 @ 1000
19-A	DRINKING WATER	LEAD	12/20/23 @ 1000
19-B	DRINKING WATER	LEAD	12/20/23 @ 1000
20-A	DRINKING WATER	LEAD	12/20/23 @ 1000
20-B	DRINKING WATER	LEAD	12/20/23 @ 1000
21-A	DRINKING WATER	LEAD	12/20/23 @ 1000
21-B	DRINKING WATER	LEAD	12/20/23 @ 1000
22-A	DRINKING WATER	LEAD	12/20/23 @ 1000
22-B	DRINKING WATER	LEAD	12/20/23 @ 1000
23-A	DRINKING WATER	LEAD	12/20/23 @ 1000
23-B	DRINKING WATER	LEAD	12/20/23 @ 1000
24-A	DRINKING WATER	LEAD	12/20/23 @ 1000



24-B	DRINKING WATER	LEAD	12/20/23 @ 1000
25-A	DRINKING WATER	LEAD	12/20/23 @ 1000
25-B	DRINKING WATER	LEAD	12/20/23 @ 1000
26-A	DRINKING WATER	LEAD	12/20/23 @ 1000
B121749 -001 26-B	DRINKING WATER	LEAD	12/20/23 @ 1000
-002 27-A	DRINKING WATER	LEAD	12/20/23 @ 1000
-003 27-B	DRINKING WATER	LEAD	12/20/23 @ 1000
-004 28-A	DRINKING WATER	LEAD	12/20/23 @ 1000
-005 28-B	DRINKING WATER	LEAD	12/20/23 @ 1000
-006 29-A	DRINKING WATER	LEAD	12/20/23 @ 1000
-007 29-B	DRINKING WATER	LEAD	12/20/23 @ 1000
-008 30-A	DRINKING WATER	LEAD	12/20/23 @ 1000
-009 30-B	DRINKING WATER	LEAD	12/20/23 @ 1000
-010 31-A	DRINKING WATER	LEAD	12/20/23 @ 1000
-011 31-B	DRINKING WATER	LEAD	12/20/23 @ 1000
-012 32-A	DRINKING WATER	LEAD	12/20/23 @ 1000
-013 32-B	DRINKING WATER	LEAD	12/20/23 @ 1000
-014 33-A	DRINKING WATER	LEAD	12/20/23 @ 1000
-015 33-B	DRINKING WATER	LEAD	12/20/23 @ 1000
-016 34-A	DRINKING WATER	LEAD	12/20/23 @ 1000
-017 34-B	DRINKING WATER	LEAD	12/20/23 @ 1000
-018 35-A	DRINKING WATER	LEAD	12/20/23 @ 1000
-019 35-B	DRINKING WATER	LEAD	12/20/23 @ 1000
-020 36-A	DRINKING WATER	LEAD	12/20/23 @ 1000
-021 36-B	DRINKING WATER	LEAD	12/20/23 @ 1000
[REDACTED]	DRINKING WATER	LEAD	12/20/23 @ 1000
[REDACTED]	DRINKING WATER	LEAD	12/20/23 @ 1000
[REDACTED]	DRINKING WATER	LEAD	12/20/23 @ 1000
[REDACTED]	DRINKING WATER	LEAD	12/20/23 @ 1000
-022 39-A	DRINKING WATER	LEAD	12/20/23 @ 1000
-023 39-B	DRINKING WATER	LEAD	12/20/23 @ 1000
-024 40-A	DRINKING WATER	LEAD	12/20/23 @ 1000
-025 40-B	DRINKING WATER	LEAD	12/20/23 @ 1000
-026 41-A	DRINKING WATER	LEAD	12/20/23 @ 1000
-027 41-B	DRINKING WATER	LEAD	12/20/23 @ 1000
-029 42-A	DRINKING WATER	LEAD	12/20/23 @ 1000
-030 42-B	DRINKING WATER	LEAD	12/20/23 @ 1000
[REDACTED]	DRINKING WATER	LEAD	12/20/23 @ 1000
[REDACTED]	DRINKING WATER	LEAD	12/20/23 @ 1000
-031 44-A	DRINKING WATER	LEAD	12/20/23 @ 1000
-032 44-B	DRINKING WATER	LEAD	12/20/23 @ 1000
-033 45-A	DRINKING WATER	LEAD	12/20/23 @ 1000
-034 45-B	DRINKING WATER	LEAD	12/20/23 @ 1000
-035 46-A	DRINKING WATER	LEAD	12/20/23 @ 1000
-036 46-B	DRINKING WATER	LEAD	12/20/23 @ 1000
-037 47-A	DRINKING WATER	LEAD	12/20/23 @ 1000
-038 47-B	DRINKING WATER	LEAD	12/20/23 @ 1000

23121739 / 23121744

