

http://www.teklabinc.com/

February 07, 2024

John Cable Triangle 17855 Elk Prairie Drive P.O. Box 1026 Rolla, MO 65402 TEL: (573) 364-1864 FAX: (573) 364-4782



RE: RPS-ROLLA HIGH SCHOOL NEW WING

WorkOrder: 24011196

Dear John Cable:

TEKLAB, INC received 85 samples on 1/17/2024 2:28:00 PM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

Marin J. Darling I

Marvin L. Darling Project Manager (618)344-1004 ex 41 mdarling@teklabinc.com



Report Contents

http://www.teklabinc.com/

Client: Triangle

Client Project: RPS-ROLLA HIGH SCHOOL NEW WING

Work Order: 24011196 Report Date: 07-Feb-24

This reporting package includes the following:

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Receiving Check List	9
Chain of Custody	Appended



Definitions

http://www.teklabinc.com/

Client: Triangle

Client Project: RPS-ROLLA HIGH SCHOOL NEW WING

Work Order: 24011196

Report Date: 07-Feb-24

Abbr Definition

- * Analytes on report marked with an asterisk are not NELAP accredited
- CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.
- CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.
- DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.
- DNI Did not ignite
- DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.
- ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.
- IDPH IL Dept. of Public Health
- LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.
- LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).
- MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.
- MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."
- MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).
- MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).
- MW Molecular weight
- NC Data is not acceptable for compliance purposes
- ND Not Detected at the Reporting Limit
- NELAP NELAP Accredited
 - PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.
 - RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.
 - RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).
 - SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.
 - Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.
 - TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"
- TNTC Too numerous to count (> 200 CFU)



Definitions

http://www.teklabinc.com/

Work Order: 24011196

Report Date: 07-Feb-24

Client: Triangle

Client Project: RPS-ROLLA HIGH SCHOOL NEW WING

- # Unknown hydrocarbon
- C RL shown is a Client Requested Quantitation Limit
- H Holding times exceeded
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
 - S Spike Recovery outside recovery limits
 - X Value exceeds Maximum Contaminant Level

Qualifiers

- B Analyte detected in associated Method Blank
- E Value above quantitation range
- I Associated internal standard was outside method criteria
- M Manual Integration used to determine area response
- R RPD outside accepted recovery limits
- T TIC(Tentatively identified compound)



Case Narrative

http://www.teklabinc.com/

Client: Triangle
Client Project: RPS-ROLLA HIGH SCHOOL NEW WING

Cooler Receipt Temp: NA °C

Work Order: 24011196 Report Date: 07-Feb-24

			Locations		
	Collinsville		Springfield		Kansas City
Address	5445 Horseshoe Lake Road	Address	3920 Pintail Dr	Address	8421 Nieman Road
	Collinsville, IL 62234-7425		Springfield, IL 62711-9415		Lenexa, KS 66214
Phone	(618) 344-1004	Phone	(217) 698-1004	Phone	(913) 541-1998
Fax	(618) 344-1005	Fax	(217) 698-1005	Fax	(913) 541-1998
Email	jhriley@teklabinc.com	Email	KKlostermann@teklabinc.com	Email	jhriley@teklabinc.com
	Collinsville Air		Chicago		
Address	5445 Horseshoe Lake Road	Address	1319 Butterfield Rd.		
	Collinsville, IL 62234-7425		Downers Grove, IL 60515		
Phone	(618) 344-1004	Phone	(630) 324-6855		
Fax	(618) 344-1005	Fax			
Email	EHurley@teklabinc.com	Email	arenner@teklabinc.com		



Accreditations

http://www.teklabinc.com/

Client: Triangle

Client Project: RPS-ROLLA HIGH SCHOOL NEW WING

Work Order: 24011196 Report Date: 07-Feb-24

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2025	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2024	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2025	Collinsville
Missouri	MDNR	00930		10/31/2026	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



http://www.teklabinc.com/

Work Order: 24011196

Report Date: 07-Feb-24

Client: Triangle

Client Project: RPS-ROLLA HIGH SCHOOL NEW WING

Matrix: DF	INKING WATER
------------	--------------

Sample ID	Client Sample ID	Certification	Qual RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4	4, 200.8 R5.4, META	LS BY ICPMS (1	TOTAL)					
Lead								
24011196-001	A 1-A	NELAP	0.0010	< 0.0010	mg/L	1	02/02/2024 7:36	01/14/2024 10:30
24011196-002	2A 1-B	NELAP	0.0010	< 0.0010	mg/L	1	02/02/2024 7:40	01/14/2024 10:30
24011196-003	8A 2-A	NELAP	0.0010	< 0.0010	mg/L	1	02/02/2024 7:44	01/14/2024 10:30
24011196-004	A 2-B	NELAP	0.0010	< 0.0010	mg/L	1	02/02/2024 7:48	01/14/2024 10:30
24011196-005	6A 3-A	NELAP	0.0010	0.0098	mg/L	1	02/02/2024 7:52	01/14/2024 10:30
24011196-006	6A 3-B	NELAP	0.0010	< 0.0010	mg/L	1	02/02/2024 7:56	01/14/2024 10:30
24011196-007	'A 4-A	NELAP	0.0010	0.0051	mg/L	1	02/02/2024 8:04	01/14/2024 10:30
24011196-008	A 4-B	NELAP	0.0010	< 0.0010	mg/L	1	02/02/2024 8:00	01/14/2024 10:30
24011196-009	A 5-A	NELAP	0.0010	0.0041	mg/L	1	02/02/2024 8:29	01/14/2024 10:30
24011196-010	A 5-B	NELAP	0.0010	< 0.0010	mg/L	1	02/02/2024 8:33	01/14/2024 10:30
24011196-011	A 6-A	NELAP	0.0010	< 0.0010	mg/L	1	02/02/2024 8:37	01/14/2024 10:30
24011196-012	2A 6-B	NELAP	0.0010	< 0.0010	mg/L	1	02/02/2024 8:41	01/14/2024 10:30
24011196-013	8A 7-A	NELAP	0.0010	0.0042	mg/L	1	02/02/2024 8:46	01/14/2024 10:30
24011196-014	A 7-B	NELAP	0.0010	< 0.0010	mg/L	1	02/02/2024 8:50	01/14/2024 10:30
24011196-015	5A 8-A	NELAP	0.0010	0.0040	mg/L	1	02/02/2024 8:58	01/14/2024 10:30
24011196-016	A 8-B	NELAP	0.0010	< 0.0010	mg/L	1	02/02/2024 8:54	01/14/2024 10:30
24011196-017	'A 9-A	NELAP	0.0010	0.0034	mg/L	1	02/02/2024 9:22	01/14/2024 10:30
24011196-018	A 9-B	NELAP	0.0010	< 0.0010	mg/L	1	02/02/2024 9:27	01/14/2024 10:30
24011196-019	A 10-A	NELAP	0.0010	0.0027	mg/L	1	02/02/2024 9:31	01/14/2024 10:30
24011196-020		NELAP	0.0010	< 0.0010	mg/L	1	02/02/2024 9:35	01/14/2024 10:30
24011196-021		NELAP	0.0010	0.0038	mg/L	1	02/02/2024 9:39	01/14/2024 10:30
24011196-022		NELAP	0.0010	0.0014	mg/L	1	02/02/2024 9:51	01/14/2024 10:30
24011196-023		NELAP	0.0010	0.0032	mg/L	1	02/02/2024 9:43	01/14/2024 10:30
24011196-024		NELAP	0.0010	< 0.0010	mg/L	1	02/02/2024 9:47	01/14/2024 10:30
24011196-025		NELAP	0.0010	0.0049	mg/L	1	02/02/2024 10:16	01/14/2024 10:30
24011196-026		NELAP	0.0010	< 0.0010	mg/L	1	02/02/2024 10:20	01/14/2024 10:30
24011196-027		NELAP	0.0010	0.0043	mg/L	1	02/02/2024 10:24	01/14/2024 10:30
24011196-028		NELAP	0.0010	0.0012	mg/L	1	02/02/2024 10:28	01/14/2024 10:30
24011196-029		NELAP	0.0010	0.0036	mg/L	1	02/02/2024 10:32	01/14/2024 10:30
24011196-030		NELAP	0.0010	< 0.0010	mg/L	1	02/02/2024 10:36	01/14/2024 10:30
24011196-031		NELAP	0.0010	< 0.0010	mg/L	1	02/02/2024 10:40	01/14/2024 10:30
24011196-032		NELAP	0.0010	< 0.0010	mg/L	1	02/02/2024 11:09	01/14/2024 10:30
24011196-033		NELAP	0.0010	< 0.0010	mg/L	1	02/02/2024 11:13	01/14/2024 10:30
24011196-034		NELAP	0.0010	< 0.0010	mg/L	1	02/02/2024 10:44	01/14/2024 10:30
24011196-035		NELAP	0.0010	0.0041	mg/L	1	02/02/2024 11:17	01/14/2024 10:30
24011196-036		NELAP	0.0010	< 0.0010	mg/L	1	02/02/2024 11:21	01/14/2024 10:30
24011196-037		NELAP	0.0010	0.0122	mg/L	1	02/02/2024 11:26	01/14/2024 10:30
24011196-038		NELAP	0.0010	< 0.0010	mg/L	5	02/02/2024 9:49	01/14/2024 10:30
24011196-039		NELAP	0.0010	0.0079	mg/L	1	02/02/2024 11:30	01/14/2024 10:30
24011196-040		NELAP	0.0010	< 0.0010	mg/L	1	02/02/2024 11:34	01/14/2024 10:30
24011196-040		NELAP	0.0010	0.0074	mg/L	1	02/02/2024 9:14	01/14/2024 10:30
24011196-041		NELAP	0.0010	< 0.0014	mg/L	1	02/02/2024 9:14	01/14/2024 10:30
24011196-043		NELAP	0.0010	0.0055	mg/L	1	02/03/2024 5:40	01/14/2024 10:30
24011196-044		NELAP	0.0010	< 0.0035	mg/L	1	02/05/2024 22:45	01/14/2024 10:30
24011196-045		NELAP	0.0010	0.0060	mg/L	1	02/07/2024 9:01	01/14/2024 10:30
24011196-045		NELAP	0.0010	< 0.0010	mg/L	1	02/06/2024 9:01	01/14/2024 10:30
24011196-040		NELAP	0.0010	0.0034	mg/L	1	02/06/2024 16:38	01/14/2024 10:30
24011196-047		NELAP	0.0010	< 0.0034	mg/L	1	02/03/2024 7:34	01/14/2024 10:30
_ 1011100-040			0.0010	< 0.0010	<u>9</u> , L			2age 7 of 9



http://www.teklabinc.com/

Work Order: 24011196

Report Date: 07-Feb-24

Client: Triangle

Client Project: RPS-ROLLA HIGH SCHOOL NEW WING

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4	4, 200.8 R5.4, META	LS BY ICPMS (TOTAL)					
Lead			,					
24011196-049	A 25-A	NELAP	0.0010	0.0011	mg/L	1	02/03/2024 7:38	01/14/2024 10:30
24011196-050	A 25-B	NELAP	0.0010	< 0.0010	mg/L	5	02/06/2024 15:55	01/14/2024 10:30
24011196-051	A 26-A	NELAP	0.0010	< 0.0010	mg/L	5	02/02/2024 9:40	01/14/2024 10:30
24011196-052	A 26-B	NELAP	0.0010	< 0.0010	mg/L	5	02/02/2024 9:44	01/14/2024 10:30
24011196-053	A 27-A	NELAP	0.0010	0.0038	mg/L	5	02/06/2024 16:25	01/14/2024 10:30
24011196-054	A 27-B	NELAP	0.0010	< 0.0010	mg/L	5	02/06/2024 16:30	01/14/2024 10:30
24011196-055	A 28-A	NELAP	0.0010	0.0050	mg/L	1	02/03/2024 7:41	01/14/2024 10:30
24011196-056	A 28-B	NELAP	0.0010	< 0.0010	mg/L	1	02/03/2024 7:45	01/14/2024 10:30
24011196-057	A 29-A	NELAP	0.0010	0.0082	mg/L	1	02/03/2024 7:49	01/14/2024 10:30
24011196-058	A 29-B	NELAP	0.0010	< 0.0010	mg/L	1	02/03/2024 8:00	01/14/2024 10:30
24011196-059	A 30-A	NELAP	0.0010	0.0065	mg/L	1	02/03/2024 8:03	01/14/2024 10:30
24011196-060	A 30-B	NELAP	0.0010	< 0.0010	mg/L	1	02/03/2024 8:18	01/14/2024 10:30
24011196-061	A 31-A	NELAP	0.0010	0.0027	mg/L	1	02/03/2024 8:22	01/14/2024 10:30
24011196-062	A 31-B	NELAP	0.0010	< 0.0010	mg/L	1	02/03/2024 8:25	01/14/2024 10:30
24011196-063	A 32-A	NELAP	0.0010	0.0149	mg/L	5	02/03/2024 5:18	01/14/2024 10:30
24011196-064	A 32-B	NELAP	0.0010	0.0020	mg/L	5	02/06/2024 15:59	01/14/2024 10:30
24011196-065	A 33-A	NELAP	0.0010	0.0131	mg/L	5	02/03/2024 5:33	01/14/2024 10:30
24011196-066	A 33-B	NELAP	0.0010	< 0.0010	mg/L	5	02/06/2024 16:34	01/14/2024 10:30
24011196-067	A 34-A	NELAP	0.0010	< 0.0010	mg/L	1	02/03/2024 8:36	01/14/2024 10:30
24011196-068	A 34-B	NELAP	0.0010	< 0.0010	mg/L	1	02/03/2024 8:40	01/14/2024 10:30
24011196-069	A 35-A	NELAP	0.0010	< 0.0010	mg/L	1	02/01/2024 19:08	01/14/2024 10:30
24011196-070	A 35-B	NELAP	0.0010	< 0.0010	mg/L	5	02/01/2024 23:19	01/14/2024 10:30
24011196-071	A 36-A	NELAP	0.0010	0.0035	mg/L	1	02/03/2024 8:44	01/14/2024 10:30
24011196-072	A 36-B	NELAP	0.0010	0.0011	mg/L	1	02/03/2024 8:47	01/14/2024 10:30
24011196-073	A 37-A	NELAP	0.0010	0.0032	mg/L	1	02/01/2024 18:37	01/14/2024 10:30
24011196-074	A 37-B	NELAP	0.0010	0.0011	mg/L	1	02/01/2024 18:42	01/14/2024 10:30
24011196-075	A 38-A	NELAP	0.0010	0.0038	mg/L	1	02/01/2024 18:46	01/14/2024 10:30
24011196-076	A 38-B	NELAP	0.0010	0.0012	mg/L	1	02/03/2024 8:51	01/14/2024 10:30
24011196-077	A 39-A	NELAP	0.0010	0.0096	mg/L	5	02/01/2024 23:24	01/14/2024 10:30
24011196-078	A 39-B	NELAP	0.0010	0.0021	mg/L	1	02/01/2024 20:04	01/14/2024 10:30
24011196-079	A 40-A	NELAP	0.0010	0.0111	mg/L	1	02/01/2024 18:55	01/14/2024 10:30
24011196-080	A 40-B	NELAP	0.0010	0.0022	mg/L	1	02/01/2024 18:59	01/14/2024 10:30
24011196-081	A 41-A	NELAP	0.0010	0.0089	mg/L	5	02/01/2024 23:30	01/14/2024 10:30
24011196-082	A 41-B	NELAP	0.0010	0.0018	mg/L	5	02/03/2024 9:31	01/14/2024 10:30
24011196-083	A 42-A	NELAP	0.0010	0.0055	mg/L	5	02/03/2024 9:35	01/14/2024 10:30
24011196-084	A 42-B	NELAP	0.0010	< 0.0010	mg/L	1	02/01/2024 19:03	01/14/2024 10:30
24011196-085	A ICE	NELAP	0.0010	< 0.0010	mg/L	5	02/01/2024 23:45	01/14/2024 10:30



Receiving Check List

http://www.teklabinc.com/

Client: Triangle

Client Project: RPS-ROLLA HIGH SCHOOL NEW WING

Work Order: 24011196 Report Date: 07-Feb-24

Carrier: John Cable	Received By:	LEH								
Completed by: Mary E. Kemp On: 17-Jan-24 Mary E Kemp	Reviewed by On: 17-Jan-24	Elled Hopker Ellie Hopkins	N							
Pages to follow: Chain of custody 1	Extra pages included 2									
Shipping container/cooler in good condition?	Yes 🗸 No	Not Present	Temp °C NA							
Type of thermal preservation?	None 🖌 Ice		Dry Ice							
Chain of custody present?	Yes 🖌 No		,							
Chain of custody signed when relinquished and received?	Yes 🖌 No									
Chain of custody agrees with sample labels?	Yes 🖌 No									
Samples in proper container/bottle?	Yes 🖌 No									
Sample containers intact?	Yes 🖌 No									
Sufficient sample volume for indicated test?	Yes 🖌 No									
All samples received within holding time?	Yes 🖌 No									
Reported field parameters measured:	Field Lab	□ NA 🗹								
Container/Temp Blank temperature in compliance?	Yes 🗹 No									
When thermal preservation is required, samples are compliant with a temperature between 0.1° C - 6.0° C, or when samples are received on ice the same day as collected.										
Water – at least one vial per sample has zero headspace?	Yes 🗌 No	No VOA vials 🗸								
Water - TOX containers have zero headspace?	Yes 🗌 No	No TOX containers								
Water - pH acceptable upon receipt?	Yes 🗹 No									
NPDES/CWA TCN interferences checked/treated in the field?	Yes 🗌 No	□ NA 🗹								
Any No responses must be detailed below or on the COC.										

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory.

CHAIN OF CUSTODY

Pg 1 of Workorder # 24011196

TEKLAB INC, 5445 Horseshoe Lake Road, Collinsville, IL 62234 Phone (618) 344-1004 Fax (618) 344-1005

					1					-		_				````\	1			$\frac{1}{1}$		-	
·····	IVIRONMENTAL SCIENC	E AND ENGIN	IEERING				es on		٦.			Ľ	4	LUE	ICE	Y	₹		•	V#		C	
Address: PO BOX 1026				Pres	sen	ved i	n:	Y		в	L	F	ELD		-	FOR	LAE	<u>I US</u>	e on	LY		I	
City/State/Zip: ROLL/					LAB	B NO	DTES	: ۱	- 1 - 1	•	- 1	•							•	<u> </u>	۱.	ı.	امد
Contact: JOHN CABL	E	Phone: 57	3 308 0140	·····	K	\square	Œ	-	17	121	H	101		<u>I</u>	r	М	L)]]	Ľ	Pt	<u>14</u>	עי	Å
Email: TRIANGLE.E	ENVIRONMENTAL	Fax: @GM	AIL.COM			-	Соп			- r				١							-	1	I
Are these samples known to be involved in litigation? If yes, a surcharge will apply: Yes Yes Yes Yes Yes Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section: Yes No																<u>.</u>					<u>.</u>		
PROJECT NAME/NU	IMBER	SAMPLE CO		SNAME	# (anc	i Ty)e	of C	onta	line	rs		INI					SIS I	REQ	JES	TED)
RPS-ROLLA HIGH SC	CHOOL NEW WING	JOHN W CA	BLE																				
RES	ULTS REQUESTED		BILLIN	IG INSTRUCTIONS		ᅬ	z	Ę.	_ ≣	Na	1_	Ь	-										
Standard	1-2 Day (100% St	urcharge)	TRIANGL	E	UNP	HNO3	NaOH	H3904	휘	NaHSO4	TSP	Other	LEAD										
Other	3 Day (50% Surch	÷ ,				ω	-	2	 -	¥∣₽			-										
Lab Use Only	Sample ID	Date/Time	Sampled	Matrix																			
				Drinking Water																			
				Drinking Water																T	Π		
				Drinking Water												Τ					\Box		
l				Drinking Water																			Τ
				Drinking Water				T		T						T			T	Τ			
<u> </u>				Drinking Water												T				1	Π		
				Drinking Water						Τ						\uparrow			-	+			
				Drinking Water																1			
		[Drinking Water							1												
				Drinking Water											╈	+			+	╈	H		
				Drinking Water							1.						Π		Т	Τ			
F	Relinquished By	,	,	Date/Time		-					eive	ed E	3y	correction of the						Date	/Tim	ie	
JOHN W CABLE	Tell U/ Call	L	1/17/	29 (a) 2:00pm		4	2-(Ź	ler	<u>_</u> 20	\sim							4	7/24	<u> </u>	1	4	28
/	1		//	· · · · ·	[-															
	/		· · · ·																				
																			<u> </u>	<u> </u>			

*The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions

It Vinter

1-A	DRINKING WATER	LEAD	1/14/24 @ 1030	GLW-SHORT 2401	1196-001
1-B	DRINKING WATER	LEAD	1/14/24 @ 1030		002
2-A	DRINKING WATER	LEAD	1/14/24 @ 1030	GLW-TALL	003
2-B	DRINKING WATER	LEAD	1/14/24 @ 1030		004
3-A	DRINKING WATER	LEAD	1/14/24 @ 1030	TRAINNING ROOM	005
3-В	DRINKING WATER	LEAD	1/14/24 @ 1030		000
4-A	DRINKING WATER	LEAD	1/14/24 @ 1030	GLW-V	100
4-B	DRINKING WATER	LEAD	1/14/24 @ 1030		00%
5-A	DRINKING WATER	LEAD	1/14/24 @ 1030	GLW-V	009
5-B	DRINKING WATER	LEAD	1/14/24 @ 1030		010
6-A	DRINKING WATER	LEAD	1/14/24 @ 1030	GLW-V	010
6-B	DRINKING WATER	LEAD	1/14/24 @ 1030		012
7-A	DRINKING WATER	LEAD	1/14/24 @ 1030	PE-L	
7-B	DRINKING WATER	LEAD	1/14/24 @ 1030		013
8-A	DRINKING WATER	LEAD	1/14/24 @ 1030	PE-L	014
8-B	DRINKING WATER	LEAD	1/14/24 @ 1030		015
9-A	DRINKING WATER	LEAD	1/14/24 @ 1030	PE-L	0110
9-B	DRINKING WATER	LEAD	1/14/24 @ 1030		018
10-A	DRINKING WATER	LEAD	1/14/24 @ 1030	TM-L	019
10-B	DRINKING WATER	LEAD	1/14/24 @ 1030		020
11-A	DRINKING WATER	LEAD	1/14/24 @ 1030	TM-L	021
11-A	DRINKING WATER	LEAD	1/14/24 @ 1030	1 IV;-L	022
11-0 12-A	DRINKING WATER	LEAD	1/14/24 @ 1030	TM-L	023
12-A 12-B	DRINKING WATER	LEAD	1/14/24 @ 1030	(IVI-L	624
12-6 13-A	DRINKING WATER	LEAD	1/14/24 @ 1030	PEL-B	
13-A 13-B	DRINKING WATER	LEAD	1/14/24 @ 1030	rcl-D	025
13-6 14-A	DRINKING WATER	LEAD			626
			1/14/24 @ 1030	PEL-B	27 226
14-B	DRINKING WATER	LEAD	1/14/24 @ 1030		
15-A	DRINKING WATER	LEAD	1/14/24 @ 1030	PEL-B	029
15-B	DRINKING WATER	LEAD	1/14/24 @ 1030	DL M CHODT	030
16-A	DRINKING WATER	LEAD	1/14/24 @ 1030	BL-W-SHORT	031
16-B	DRINKING WATER	LEAD	1/14/24 @ 1030		632
17-A	DRINKING WATER	LEAD	1/14/24 @ 1030	BL-W-TALL	033
17-B	DRINKING WATER	LEAD	1/14/24 @ 1030		034
18-A	DRINKING WATER	LEAD	1/14/24 @ 1030	CONCESSION STAND	035
18-B	DRINKING WATER	LEAD	1/14/24 @ 1030		034
19-A	DRINKING WATER	LEAD	1/14/24 @ 1030	CONCESSION CLOSET	037
19-B	DRINKING WATER	LEAD	1/14/24 @ 1030		038
20-A	DRINKING WATER	LEAD	1/14/24 @ 1030	BOY-BATH	039
20-B	DRINKING WATER	LEAD	1/14/24 @ 1030		040
21-A	DRINKING WATER	LEAD	1/14/24 @ 1030	BOY-BATH	041
21-B	DRINKING WATER	LEAD	1/14/24 @ 1030		042
22-A	DRINKING WATER	LEAD	1/14/24 @ 1030	BOY-BATH	643
22-B	DRINKING WATER	LEAD	1/14/24 @ 1030		044
23-A	DRINKING WATER	LEAD	1/14/24 @ 1030	BOY-BATH	045
23-B	DRINKING WATER	LEAD	1/14/24 @ 1030		V DYLD
24-A	DRINKING WATER	LEAD	1/14/24 @ 1030	BOY-BATH	047

24-B	DRINKING WATER	LEAD	1/14/24 @ 1030		24011196-048
25-A	DRINKING WATER	LEAD	1/14/24 @ 1030	FH-W-TALL	049
25-B	DRINKING WATER	LEAD	1/14/24 @ 1030		1
26-A	DRINKING WATER	LEAD	1/14/24 @ 1030	FH-W-SHORT	050
26-B	DRINKING WATER	LEAD	1/14/24 @ 1030		051
27-A	DRINKING WATER	LEAD	1/14/24 @ 1030	GIRL-BATH	052 053
27-В	DRINKING WATER	LEAD	1/14/24 @ 1030		059
28-A	DRINKING WATER	LEAD	1/14/24 @ 1030	GIRL-BATH	055
28-B	DRINKING WATER	LEAD	1/14/24 @ 1030		420
29-A	DRINKING WATER	LEAD	1/14/24 @ 1030	GIRL-BATH	057
29-B	DRINKING WATER	LEAD	1/14/24 @ 1030		058
30-A	DRINKING WATER	LEAD	1/14/24 @ 1030	GIRL-BATH	059
30-B	DRINKING WATER	LEAD	1/14/24 @ 1030		060
31-A	DRINKING WATER	LEAD	1/14/24 @ 1030	GIRL-BATH	061
31-B	DRINKING WATER	LEAD	1/14/24 @ 1030		062
32-A	DRINKING WATER	LEAD	1/14/24 @ 1030	S-BATH	063
32-B	DRINKING WATER	LEAD	1/14/24 @ 1030		069
33-A	DRINKING WATER	LEAD	1/14/24 @ 1030	BAND	065
33-B	DRINKING WATER	LEAD	1/14/24 @ 1030		066
34-A	DRINKING WATER	LEAD	1/14/24 @ 1030	BAND-W-TALL	067
34-B	DRINKING WATER	LEAD	1/14/24 @ 1030		068
35-A	DRINKING WATER	LEAD	1/14/24 @ 1030	BAND-W-SHORT	
35-B	DRINKING WATER	LEAD	1/14/24 @ 1030		070
36-A	DRINKING WATER	LEAD	1/14/24 @ 1030	BOYS-BAND	. 071
36-B	DRINKING WATER	LEAD	1/14/24 @ 1030		677
37 - A	DRINKING WATER	LEAD	1/14/24 @ 1030	BOYS-BAND	673
37~B	DRINKING WATER	LEAD	1/14/24 @ 1030		674
38-A	DRINKING WATER	LEAD	1/14/24 @ 1030	BOYS-BAND	075
38-B	DRINKING WATER	LEAD	1/14/24 @ 1030		076
39-A	DRINKING WATER	LEAD	1/14/24 @ 1030	GIRLS-BAND	677
39-B	DRINKING WATER	LEAD	1/14/24 @ 1030		678
40-A	DRINKING WATER	LEAD	1/14/24 @ 1030	GIRLS-BAND	079
40-B	DRINKING WATER	LEAD	1/14/24 @ 1030		080
41-A	DRINKING WATER	LEAD	1/14/24 @ 1030	GIRLS-BAND	681
41-B	DRINKING WATER	LEAD	1/14/24 @ 1030		062
42-A	DRINKING WATER	LEAD	1/14/24 @ 1030	CHOIR	083
42-B	DRINKING WATER	LEAD	1/14/24 @ 1030		084
ICE	DRINKING WATER	LEAD	1/14/24 @ 1030		085
					Ja 2005