

January 30, 2024

John Cable
Triangle
17855 Elk Prairie Drive
P.O. Box 1026
Rolla, MO 65402
TEL: (573) 364-1864
FAX: (573) 364-4782



Illinois	100226
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

RE: RPS-Rolla High School

WorkOrder: 24010254

Dear John Cable:

TEKLAB, INC received 54 samples on 1/3/2024 12:57:00 PM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Marvin L. Darling
Project Manager
(618)344-1004 ex 41
mdarling@teklabinc.com



Report Contents

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010254

Client Project: RPS-Rolla High School

Report Date: 30-Jan-24

This reporting package includes the following:

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Quality Control Results	9
Receiving Check List	14
Chain of Custody	Appended

Client: Triangle

Work Order: 24010254

Client Project: RPS-Rolla High School

Report Date: 30-Jan-24

Abbr Definition

* Analytes on report marked with an asterisk are not NELAP accredited

CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.

CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.

DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.

DNI Did not ignite

DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.

ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.

IDPH IL Dept. of Public Health

LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.

LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.

MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."

MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).

MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MW Molecular weight

NC Data is not acceptable for compliance purposes

ND Not Detected at the Reporting Limit

NELAP NELAP Accredited

PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.

RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.

RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).

SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.

Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.

TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"

TNTC Too numerous to count (> 200 CFU)

Client: Triangle

Work Order: 24010254

Client Project: RPS-Rolla High School

Report Date: 30-Jan-24

Qualifiers

- # - Unknown hydrocarbon
- C - RL shown is a Client Requested Quantitation Limit
- H - Holding times exceeded
- J - Analyte detected below quantitation limits
- ND - Not Detected at the Reporting Limit
- S - Spike Recovery outside recovery limits
- X - Value exceeds Maximum Contaminant Level
- B - Analyte detected in associated Method Blank
- E - Value above quantitation range
- I - Associated internal standard was outside method criteria
- M - Manual Integration used to determine area response
- R - RPD outside accepted recovery limits
- T - TIC(Tentatively identified compound)



Case Narrative

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010254

Client Project: RPS-Rolla High School

Report Date: 30-Jan-24

Cooler Receipt Temp: N/A °C

Locations

Collinsville

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email jhriley@teklabinc.com

Collinsville Air

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email EHurley@teklabinc.com

Springfield

Address 3920 Pintail Dr
Springfield, IL 62711-9415
Phone (217) 698-1004
Fax (217) 698-1005
Email KKlostermann@teklabinc.com

Chicago

Address 1319 Butterfield Rd.
Downers Grove, IL 60515
Phone (630) 324-6855
Fax
Email arenner@teklabinc.com

Kansas City

Address 8421 Nieman Road
Lenexa, KS 66214
Phone (913) 541-1998
Fax (913) 541-1998
Email jhriley@teklabinc.com



Accreditations

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010254

Client Project: RPS-Rolla High School

Report Date: 30-Jan-24

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2025	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2024	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2024	Collinsville
Missouri	MDNR	00930		5/31/2023	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



Laboratory Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010254

Client Project: RPS-Rolla High School

Report Date: 30-Jan-24

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)									
Lead									
24010254-001A	151-A	NELAP		0.0010	0.0092	mg/L	1	01/18/2024 15:19	12/30/2023 10:00
24010254-002A	151-B	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 15:23	12/30/2023 10:00
24010254-003A	152-A	NELAP		0.0010	0.0107	mg/L	1	01/18/2024 15:53	12/30/2023 10:00
24010254-004A	152-B	NELAP		0.0010	0.0012	mg/L	1	01/18/2024 15:57	12/30/2023 10:00
24010254-005A	153-A	NELAP		0.0010	0.0068	mg/L	1	01/18/2024 15:27	12/30/2023 10:00
24010254-006A	153-B	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 16:02	12/30/2023 10:00
24010254-007A	154-A	NELAP		0.0010	0.0090	mg/L	1	01/18/2024 16:06	12/30/2023 10:00
24010254-008A	154-B	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 16:10	12/30/2023 10:00
24010254-009A	155-A	NELAP		0.0010	0.0045	mg/L	1	01/18/2024 16:15	12/30/2023 10:00
24010254-010A	155-B	NELAP		0.0010	0.0099	mg/L	5	01/17/2024 7:56	12/30/2023 10:00
24010254-011A	156-A	NELAP		0.0010	0.0164	mg/L	1	01/18/2024 16:19	12/30/2023 10:00
24010254-012A	156-B	NELAP		0.0010	0.0072	mg/L	5	01/30/2024 6:48	12/30/2023 10:00
24010254-013A	157-A	NELAP		0.0010	0.0154	mg/L	1	01/18/2024 16:23	12/30/2023 10:00
24010254-014A	157-B	NELAP		0.0010	0.0024	mg/L	5	01/17/2024 8:01	12/30/2023 10:00
24010254-015A	158-A	NELAP		0.0010	0.0045	mg/L	1	01/18/2024 16:49	12/30/2023 10:00
24010254-016A	158-B	NELAP		0.0010	0.0023	mg/L	5	01/17/2024 8:06	12/30/2023 10:00
24010254-017A	159-A	NELAP		0.0010	0.0070	mg/L	1	01/18/2024 16:54	12/30/2023 10:00
24010254-018A	159-B	NELAP		0.0010	0.0015	mg/L	5	01/24/2024 7:35	12/30/2023 10:00
24010254-019A	160-A	NELAP		0.0010	0.0038	mg/L	1	01/18/2024 16:58	12/30/2023 10:00
24010254-020A	160-B	NELAP		0.0010	0.0016	mg/L	5	01/24/2024 7:39	12/30/2023 10:00
24010254-021A	161-A	NELAP		0.0010	0.0046	mg/L	1	01/18/2024 17:02	12/30/2023 10:00
24010254-022A	161-B	NELAP		0.0010	0.0013	mg/L	5	01/24/2024 7:43	12/30/2023 10:00
24010254-023A	162-A	NELAP		0.0010	0.0045	mg/L	1	01/18/2024 17:19	12/30/2023 10:00
24010254-024A	162-B	NELAP		0.0010	0.0071	mg/L	5	01/24/2024 7:48	12/30/2023 10:00
24010254-025A	163-A	NELAP		0.0010	0.0070	mg/L	1	01/18/2024 17:06	12/30/2023 10:00
24010254-026A	163-B	NELAP		0.0010	0.0070	mg/L	5	01/24/2024 7:56	12/30/2023 10:00
24010254-027A	164-A	NELAP		0.0010	0.0767	mg/L	5	01/24/2024 7:52	12/30/2023 10:00
24010254-028A	164-B	NELAP		0.0010	0.0026	mg/L	5	01/24/2024 8:31	12/30/2023 10:00
24010254-029A	165-A	NELAP		0.0010	0.0174	mg/L	1	01/18/2024 17:11	12/30/2023 10:00
24010254-030A	165-B	NELAP		0.0010	0.0018	mg/L	1	01/18/2024 17:15	12/30/2023 10:00
24010254-031A	166-A	NELAP		0.0010	0.0021	mg/L	1	01/23/2024 23:04	12/30/2023 10:00
24010254-032A	166-B	NELAP		0.0010	0.0017	mg/L	1	01/23/2024 23:19	12/30/2023 10:00
24010254-033A	167-A	NELAP		0.0010	0.0030	mg/L	1	01/23/2024 23:22	12/30/2023 10:00
24010254-034A	167-B	NELAP		0.0010	0.0028	mg/L	5	01/24/2024 8:36	12/30/2023 10:00
24010254-035A	168-A	NELAP		0.0010	0.0044	mg/L	1	01/24/2024 9:41	12/30/2023 10:00
24010254-036A	168-B	NELAP		0.0010	0.0027	mg/L	5	01/24/2024 8:40	12/30/2023 10:00
24010254-037A	169-A	NELAP		0.0010	0.0240	mg/L	1	01/23/2024 23:37	12/30/2023 10:00
24010254-038A	169-B	NELAP		0.0010	0.0024	mg/L	5	01/17/2024 8:21	12/30/2023 10:00
24010254-039A	170-A	NELAP		0.0010	0.0026	mg/L	5	01/17/2024 8:11	12/30/2023 10:00
24010254-040A	170-B	NELAP		0.0010	0.0030	mg/L	5	01/17/2024 8:16	12/30/2023 10:00
24010254-041A	171-A	NELAP		0.0010	0.0059	mg/L	5	01/17/2024 3:06	12/30/2023 10:00
24010254-042A	171-B	NELAP		0.0010	0.0012	mg/L	5	01/17/2024 3:11	12/30/2023 10:00
24010254-043A	172-A	NELAP		0.0010	0.0089	mg/L	5	01/17/2024 3:16	12/30/2023 10:00
24010254-044A	172-B	NELAP		0.0010	< 0.0010	mg/L	5	01/17/2024 3:21	12/30/2023 10:00
24010254-045A	173-A	NELAP		0.0010	0.0253	mg/L	5	01/17/2024 3:26	12/30/2023 10:00
24010254-046A	173-B	NELAP		0.0010	< 0.0010	mg/L	1	01/23/2024 23:41	12/30/2023 10:00
24010254-047A	174-A	NELAP		0.0010	< 0.0010	mg/L	1	01/23/2024 23:44	12/30/2023 10:00
24010254-048A	174-B	NELAP		0.0010	< 0.0010	mg/L	1	01/23/2024 23:48	12/30/2023 10:00



Laboratory Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010254

Client Project: RPS-Rolla High School

Report Date: 30-Jan-24

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)									
Lead									
24010254-049A	175-A	NELAP	0.0010		0.0227	mg/L	5	01/17/2024 3:31	12/30/2023 10:00
24010254-050A	175-B	NELAP	0.0010		0.0030	mg/L	5	01/17/2024 3:36	12/30/2023 10:00
24010254-051A	176-A	NELAP	0.0010		0.0469	mg/L	5	01/17/2024 3:42	12/30/2023 10:00
24010254-052A	176-B	NELAP	0.0010		0.0018	mg/L	5	01/17/2024 9:03	12/30/2023 10:00
24010254-053A	ICE-1	NELAP	0.0010		< 0.0010	mg/L	1	01/23/2024 23:52	12/30/2023 10:00
24010254-054A	ICE-2	NELAP	0.0010		< 0.0010	mg/L	1	01/24/2024 0:06	12/30/2023 10:00



Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010254

Client Project: RPS-Rolla High School

Report Date: 30-Jan-24

EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch 217078		SampType: MBLK		Units mg/L						
SampID: MBLK-217078										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/17/2024

Batch 217078		SampType: LCS		Units mg/L						
SampID: LCS-217078										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		0.0500	0.0500	0	100.0	85	115	01/17/2024

Batch 217078		SampType: MS		Units mg/L						
SampID: 24010254-035AMS										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010	E	0.107	0.1000	0.004353	102.9	70	130	01/24/2024

Batch 217078		SampType: MSD		Units mg/L					RPD Limit: 20		Date Analyzed
SampID: 24010254-035AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010	E	0.105	0.1000	0.004353	100.5	0.1072	2.24	01/24/2024	

Batch 217079		SampType: MBLK		Units mg/L						
SampID: MBLK-217079										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/17/2024

Batch 217079		SampType: LCS		Units mg/L						
SampID: LCS-217079										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		0.0500	0.0500	0	100.0	85	115	01/17/2024

Batch 217079		SampType: MS		Units mg/L						
SampID: 24010280-003AMS										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		0.0899	0.1000	0.003813	86.1	70	130	01/23/2024

Batch 217079		SampType: MSD		Units mg/L					RPD Limit: 20		Date Analyzed
SampID: 24010280-003AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010		0.0972	0.1000	0.003813	93.4	0.08987	7.86	01/23/2024	



Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010254

Client Project: RPS-Rolla High School

Report Date: 30-Jan-24

EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch 217084		SampType: MBLK		Units mg/L							
SampID: MBLK-217084											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/17/2024	

Batch 217084		SampType: LCS		Units mg/L							
SampID: LCS-217084											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.0500	0.0500	0	100.0	85	115	01/17/2024	

Batch 217084		SampType: MS		Units mg/L							
SampID: 24010254-005AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.0976	0.1000	0.006806	90.8	70	130	01/18/2024	

Batch 217084		SampType: MSD		Units mg/L							
SampID: 24010254-005AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010		0.0977	0.1000	0.006806	90.9	0.09759	0.11	01/18/2024	

Batch 217084		SampType: MS		Units mg/L							
SampID: 24010254-013AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010	E	0.120	0.1000	0.01543	104.5	70	130	01/18/2024	

Batch 217084		SampType: MSD		Units mg/L							
SampID: 24010254-013AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010	E	0.109	0.1000	0.01543	93.4	0.1199	9.72	01/18/2024	

Batch 217087		SampType: MBLK		Units mg/L							
SampID: MBLK-217087											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/17/2024	

Batch 217087		SampType: LCS		Units mg/L							
SampID: LCS-217087											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.0500	0.0500	0	100.0	85	115	01/17/2024	



Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010254

Client Project: RPS-Rolla High School

Report Date: 30-Jan-24

EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch 217087		SampType: MS		Units mg/L							
SampID: 24010254-023AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010	E	0.115	0.1000	0.004465	110.8	70	130	01/18/2024	

Batch 217087		SampType: MSD		Units mg/L							
SampID: 24010254-023AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010	E	0.107	0.1000	0.004465	102.8	0.1153	7.21	01/18/2024	

Batch 217240		SampType: MBLK		Units mg/L							
SampID: MBLK-217240											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/17/2024	

Batch 217240		SampType: LCS		Units mg/L							
SampID: LCS-217240											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.535	0.5000	0	107.1	85	115	01/17/2024	

Batch 217240		SampType: MS		Units mg/L							
SampID: 24010254-038AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.533	0.5000	0.002410	106.1	70	130	01/17/2024	

Batch 217240		SampType: MSD		Units mg/L							
SampID: 24010254-038AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010		0.548	0.5000	0.002410	109.2	0.5332	2.80	01/17/2024	

Batch 217240		SampType: MS		Units mg/L							
SampID: 24010254-051AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010	E	0.537	0.5000	0.04692	98.1	70	130	01/17/2024	

Batch 217240		SampType: MSD		Units mg/L							
SampID: 24010254-051AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010	E	0.531	0.5000	0.04692	96.8	0.5375	1.27	01/17/2024	



Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010254

Client Project: RPS-Rolla High School

Report Date: 30-Jan-24

EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch 217367		SampType: MBLK		Units mg/L							
SampID: MBLK-217367											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/26/2024	

Batch 217367		SampType: MS		Units mg/L							
SampID: 24010502-010AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.490	0.5000	0.001065	97.7	70	130	01/26/2024	

Batch 217367		SampType: MSD		Units mg/L							
SampID: 24010502-010AMSD											
										RPD Limit: 20	
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010	E	0.543	0.5000	0.001065	108.3	0.4896	10.30	01/26/2024	

Batch 217423		SampType: MBLK		Units mg/L							
SampID: MBLK-217423											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/24/2024	

Batch 217423		SampType: LCS		Units mg/L							
SampID: LCS-217423											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.455	0.5000	0	91.0	85	115	01/24/2024	

Batch 217423		SampType: MS		Units mg/L							
SampID: 24010254-026AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.446	0.5000	0.007035	87.9	70	130	01/24/2024	

Batch 217423		SampType: MSD		Units mg/L							
SampID: 24010254-026AMSD											
										RPD Limit: 20	
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010		0.441	0.5000	0.007035	86.8	0.4464	1.15	01/24/2024	

Batch 217423		SampType: MS		Units mg/L							
SampID: 24011095-001BMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.477	0.5000	0.002436	95.0	70	130	01/24/2024	



Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010254

Client Project: RPS-Rolla High School

Report Date: 30-Jan-24

EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch	SampType:	MSD	Units	mg/L	RPD Limit:	20					Date
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Analyzed	
Lead		0.0010		0.437	0.5000	0.002436	86.8	0.4774	8.94	01/24/2024	



Receiving Check List

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010254

Client Project: RPS-Rolla High School

Report Date: 30-Jan-24

Carrier: Employee

Received By: LEH

Completed by:

Amber Dilallo

Reviewed by:

Ellie Hopkins

On:

03-Jan-24

Amber Dilallo

On:

03-Jan-24

Ellie Hopkins

Pages to follow: Chain of custody

Extra pages included

- | | | | | |
|---|--|------------------------------|--|----------------------------------|
| Shipping container/cooler in good condition? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | Not Present <input type="checkbox"/> | Temp °C N/A |
| Type of thermal preservation? | None <input checked="" type="checkbox"/> | Ice <input type="checkbox"/> | Blue Ice <input type="checkbox"/> | Dry Ice <input type="checkbox"/> |
| Chain of custody present? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Chain of custody signed when relinquished and received? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Chain of custody agrees with sample labels? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Samples in proper container/bottle? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Sample containers intact? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Sufficient sample volume for indicated test? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| All samples received within holding time? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Reported field parameters measured: | Field <input type="checkbox"/> | Lab <input type="checkbox"/> | NA <input checked="" type="checkbox"/> | |
| Container/Temp Blank temperature in compliance? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |

When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.

- | | | | |
|---|---|-----------------------------|---|
| Water – at least one vial per sample has zero headspace? | Yes <input type="checkbox"/> | No <input type="checkbox"/> | No VOA vials <input checked="" type="checkbox"/> |
| Water - TOX containers have zero headspace? | Yes <input type="checkbox"/> | No <input type="checkbox"/> | No TOX containers <input checked="" type="checkbox"/> |
| Water - pH acceptable upon receipt? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | NA <input type="checkbox"/> |
| NPDES/CWA TCN interferences checked/treated in the field? | Yes <input type="checkbox"/> | No <input type="checkbox"/> | NA <input checked="" type="checkbox"/> |

Any No responses must be detailed below or on the COC.

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory.

CHAIN OF CUSTODY

TEKLAB INC. 5445 Horseshoe Lake Road, Collinsville, IL 62234 Phone (618) 344-1004 Fax (618) 344-1005

Client: TRIANGLE ENVIRONMENTAL SCIENCE AND ENGINEERING
 Address: PO BOX 1026
 City/State/Zip: ROLLA, MO 65402
 Contact: JOHN CABLE Phone: 573 308 0140
 Email: TRIANGLE.ENVIRONMENTAL Fax: @GMAIL.COM

Samples on: ICE BLUE ICE NO ICE NA °C
 Preserved in: LAB FIELD FOR LAB USE ONLY
 LAB NOTES:

Are these samples known to be involved in litigation? If yes, a surcharge will apply: Yes No
 Are these samples known to be hazardous? Yes No
 Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section: Yes No

Client Comments:

PROJECT NAME/NUMBER: RPS-Rolla High School
 SAMPLE COLLECTOR'S NAME: JOHN W CABLE

and Type of Containers INDICATE ANALYSIS REQUESTED

RESULTS REQUESTED: Standard 1-2 Day (100% Surcharge) Other 3 Day (50% Surcharge)
 BILLING INSTRUCTIONS: TRIANGLE

UNP	HNO3	NaOH	H2SO4	HCl	MeOH	NaHSO4	TSP	Other										

Lab Use Only	Sample ID	Date/Time Sampled	Matrix
			Drinking Water
			Drinking Water
			Drinking Water
			Drinking Water
			Drinking Water
			Drinking Water
			Drinking Water
			Drinking Water
			Drinking Water
			Drinking Water
			Drinking Water
			Drinking Water
			Drinking Water
			Drinking Water
			Drinking Water

Relinquished By: John W Cable Date/Time: 1/2/24 @ 12:57

Received By: [Signature] Date/Time: 1/3/24 12:57

*The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions

14010249

001	1-A	DRINKING WATER	LEAD	12/30/23 @ 1000
002	1-B	DRINKING WATER	LEAD	12/30/23 @ 1000
003	2-A	DRINKING WATER	LEAD	12/30/23 @ 1000
004	2-B	DRINKING WATER	LEAD	12/30/23 @ 1000
005	3-A	DRINKING WATER	LEAD	12/30/23 @ 1000
006	3-B	DRINKING WATER	LEAD	12/30/23 @ 1000
007	4-A	DRINKING WATER	LEAD	12/30/23 @ 1000
008	4-B	DRINKING WATER	LEAD	12/30/23 @ 1000
009	5-A	DRINKING WATER	LEAD	12/30/23 @ 1000
010	5-B	DRINKING WATER	LEAD	12/30/23 @ 1000
011	6-A	DRINKING WATER	LEAD	12/30/23 @ 1000
012	6-B	DRINKING WATER	LEAD	12/30/23 @ 1000
013	7-A	DRINKING WATER	LEAD	12/30/23 @ 1000
014	7-B	DRINKING WATER	LEAD	12/30/23 @ 1000
015	8-A	DRINKING WATER	LEAD	12/30/23 @ 1000
016	8-B	DRINKING WATER	LEAD	12/30/23 @ 1000
017	9-A	DRINKING WATER	LEAD	12/30/23 @ 1000
018	9-B	DRINKING WATER	LEAD	12/30/23 @ 1000
019	10-A	DRINKING WATER	LEAD	12/30/23 @ 1000
020	10-B	DRINKING WATER	LEAD	12/30/23 @ 1000
021	11-A	DRINKING WATER	LEAD	12/30/23 @ 1000
022	11-B	DRINKING WATER	LEAD	12/30/23 @ 1000
023	12-A	DRINKING WATER	LEAD	12/30/23 @ 1000
024	12-B	DRINKING WATER	LEAD	12/30/23 @ 1000
025	13-A	DRINKING WATER	LEAD	12/30/23 @ 1000
026	13-B	DRINKING WATER	LEAD	12/30/23 @ 1000
027	14-A	DRINKING WATER	LEAD	12/30/23 @ 1000
028	14-B	DRINKING WATER	LEAD	12/30/23 @ 1000
029	15-A	DRINKING WATER	LEAD	12/30/23 @ 1000
030	15-B	DRINKING WATER	LEAD	12/30/23 @ 1000
031	16-A	DRINKING WATER	LEAD	12/30/23 @ 1000
032	16-B	DRINKING WATER	LEAD	12/30/23 @ 1000
033	17-A	DRINKING WATER	LEAD	12/30/23 @ 1000
034	17-B	DRINKING WATER	LEAD	12/30/23 @ 1000
035	18-A	DRINKING WATER	LEAD	12/30/23 @ 1000
036	18-B	DRINKING WATER	LEAD	12/30/23 @ 1000
037	19-A	DRINKING WATER	LEAD	12/30/23 @ 1000
038	19-B	DRINKING WATER	LEAD	12/30/23 @ 1000
039	20-A	DRINKING WATER	LEAD	12/30/23 @ 1000
040	20-B	DRINKING WATER	LEAD	12/30/23 @ 1000
041	21-A	DRINKING WATER	LEAD	12/30/23 @ 1000
042	21-B	DRINKING WATER	LEAD	12/30/23 @ 1000
043	22-A	DRINKING WATER	LEAD	12/30/23 @ 1000
044	22-B	DRINKING WATER	LEAD	12/30/23 @ 1000
045	23-A	DRINKING WATER	LEAD	12/30/23 @ 1000
046	23-B	DRINKING WATER	LEAD	12/30/23 @ 1000
047	24-A	DRINKING WATER	LEAD	12/30/23 @ 1000

241010249

048	24-B	DRINKING WATER	LEAD	12/30/23 @ 1000
049	25-A	DRINKING WATER	LEAD	12/30/23 @ 1000
050	25-B	DRINKING WATER	LEAD	12/30/23 @ 1000
051	26-A	DRINKING WATER	LEAD	12/30/23 @ 1000
052	26-B	DRINKING WATER	LEAD	12/30/23 @ 1000
053	27-A	DRINKING WATER	LEAD	12/30/23 @ 1000
054	27-B	DRINKING WATER	LEAD	12/30/23 @ 1000
055	28-A	DRINKING WATER	LEAD	12/30/23 @ 1000
056	28-B	DRINKING WATER	LEAD	12/30/23 @ 1000
057	29-A	DRINKING WATER	LEAD	12/30/23 @ 1000
058	29-B	DRINKING WATER	LEAD	12/30/23 @ 1000
059	30-A	DRINKING WATER	LEAD	12/30/23 @ 1000
060	30-B	DRINKING WATER	LEAD	12/30/23 @ 1000
4010 ²⁵⁰ 001	31-A	DRINKING WATER	LEAD	12/30/23 @ 1000
002	31-B	DRINKING WATER	LEAD	12/30/23 @ 1000
003	32-A	DRINKING WATER	LEAD	12/30/23 @ 1000
004	32-B	DRINKING WATER	LEAD	12/30/23 @ 1000
005	33-A	DRINKING WATER	LEAD	12/30/23 @ 1000
006	33-B	DRINKING WATER	LEAD	12/30/23 @ 1000
007	34-A	DRINKING WATER	LEAD	12/30/23 @ 1000
008	34-B	DRINKING WATER	LEAD	12/30/23 @ 1000
009	35-A	DRINKING WATER	LEAD	12/30/23 @ 1000
010	35-B	DRINKING WATER	LEAD	12/30/23 @ 1000
011	36-A	DRINKING WATER	LEAD	12/30/23 @ 1000
012	36-B	DRINKING WATER	LEAD	12/30/23 @ 1000
013	37-A	DRINKING WATER	LEAD	12/30/23 @ 1000
014	37-B	DRINKING WATER	LEAD	12/30/23 @ 1000
015	38-A	DRINKING WATER	LEAD	12/30/23 @ 1000
016	38-B	DRINKING WATER	LEAD	12/30/23 @ 1000
017	39-A	DRINKING WATER	LEAD	12/30/23 @ 1000
018	39-B	DRINKING WATER	LEAD	12/30/23 @ 1000
019	40-A	DRINKING WATER	LEAD	12/30/23 @ 1000
020	40-B	DRINKING WATER	LEAD	12/30/23 @ 1000
021	41-A	DRINKING WATER	LEAD	12/30/23 @ 1000
022	41-B	DRINKING WATER	LEAD	12/30/23 @ 1000
023	42-A	DRINKING WATER	LEAD	12/30/23 @ 1000
024	42-B	DRINKING WATER	LEAD	12/30/23 @ 1000
025	43-A	DRINKING WATER	LEAD	12/30/23 @ 1000
026	43-B	DRINKING WATER	LEAD	12/30/23 @ 1000
027	44-A	DRINKING WATER	LEAD	12/30/23 @ 1000
028	44-B	DRINKING WATER	LEAD	12/30/23 @ 1000
029	45-A	DRINKING WATER	LEAD	12/30/23 @ 1000
030	45-B	DRINKING WATER	LEAD	12/30/23 @ 1000
031	46-A	DRINKING WATER	LEAD	12/30/23 @ 1000
032	46-B	DRINKING WATER	LEAD	12/30/23 @ 1000
033	47-A	DRINKING WATER	LEAD	12/30/23 @ 1000
034	47-B	DRINKING WATER	LEAD	12/30/23 @ 1000

24010250

035	48-A	DRINKING WATER	LEAD	12/30/23 @ 1000
036	48-B	DRINKING WATER	LEAD	12/30/23 @ 1000
037	49-A	DRINKING WATER	LEAD	12/30/23 @ 1000
038	49-B	DRINKING WATER	LEAD	12/30/23 @ 1000
039	50-A	DRINKING WATER	LEAD	12/30/23 @ 1000
040	50-B	DRINKING WATER	LEAD	12/30/23 @ 1000
041	51-A	DRINKING WATER	LEAD	12/30/23 @ 1000
042	51-B	DRINKING WATER	LEAD	12/30/23 @ 1000
043	52-A	DRINKING WATER	LEAD	12/30/23 @ 1000
044	52-B	DRINKING WATER	LEAD	12/30/23 @ 1000
045	53-A	DRINKING WATER	LEAD	12/30/23 @ 1000
046	53-B	DRINKING WATER	LEAD	12/30/23 @ 1000
047	54-A	DRINKING WATER	LEAD	12/30/23 @ 1000
048	54-B	DRINKING WATER	LEAD	12/30/23 @ 1000
049	55-A	DRINKING WATER	LEAD	12/30/23 @ 1000
051	56-A	DRINKING WATER	LEAD	12/30/23 @ 1000
052	56-B	DRINKING WATER	LEAD	12/30/23 @ 1000
053	57-A	DRINKING WATER	LEAD	12/30/23 @ 1000
054	57-B	DRINKING WATER	LEAD	12/30/23 @ 1000
055	58-A	DRINKING WATER	LEAD	12/30/23 @ 1000
056	58-B	DRINKING WATER	LEAD	12/30/23 @ 1000
057	59-A	DRINKING WATER	LEAD	12/30/23 @ 1000
058	59-B	DRINKING WATER	LEAD	12/30/23 @ 1000
059	60-A	DRINKING WATER	LEAD	12/30/23 @ 1000
060	60-B	DRINKING WATER	LEAD	12/30/23 @ 1000
061	61-A	DRINKING WATER	LEAD	12/30/23 @ 1000
062	61-B	DRINKING WATER	LEAD	12/30/23 @ 1000
063	62-A	DRINKING WATER	LEAD	12/30/23 @ 1000
064	62-B	DRINKING WATER	LEAD	12/30/23 @ 1000
065	63-A	DRINKING WATER	LEAD	12/30/23 @ 1000
066	63-B	DRINKING WATER	LEAD	12/30/23 @ 1000
067	64-A	DRINKING WATER	LEAD	12/30/23 @ 1000
068	64-B	DRINKING WATER	LEAD	12/30/23 @ 1000
069	65-A	DRINKING WATER	LEAD	12/30/23 @ 1000
070	65-B	DRINKING WATER	LEAD	12/30/23 @ 1000
071	66-A	DRINKING WATER	LEAD	12/30/23 @ 1000
072	66-B	DRINKING WATER	LEAD	12/30/23 @ 1000
073	67-A	DRINKING WATER	LEAD	12/30/23 @ 1000
074	67-B	DRINKING WATER	LEAD	12/30/23 @ 1000
075	68-A	DRINKING WATER	LEAD	12/30/23 @ 1000
076	68-B	DRINKING WATER	LEAD	12/30/23 @ 1000
077	69-A	DRINKING WATER	LEAD	12/30/23 @ 1000
078	69-B	DRINKING WATER	LEAD	12/30/23 @ 1000
079	70-A	DRINKING WATER	LEAD	12/30/23 @ 1000
080	70-B	DRINKING WATER	LEAD	12/30/23 @ 1000
081	71-A	DRINKING WATER	LEAD	12/30/23 @ 1000
082	71-B	DRINKING WATER	LEAD	12/30/23 @ 1000

4010251

001
002
003
004
005
006
007
008
009
010
011
012
013
014
015
016
017
018
019
020
021
022

24010251

023	72-A	DRINKING WATER	LEAD	12/30/23 @ 1000
024	72-B	DRINKING WATER	LEAD	12/30/23 @ 1000
025	73-A	DRINKING WATER	LEAD	12/30/23 @ 1000
026	73-B	DRINKING WATER	LEAD	12/30/23 @ 1000
027	74-A	DRINKING WATER	LEAD	12/30/23 @ 1000
028	74-B	DRINKING WATER	LEAD	12/30/23 @ 1000
029	75-A	DRINKING WATER	LEAD	12/30/23 @ 1000
030	75-B	DRINKING WATER	LEAD	12/30/23 @ 1000
031	76-A	DRINKING WATER	LEAD	12/30/23 @ 1000
032	76-B	DRINKING WATER	LEAD	12/30/23 @ 1000
033	77-A	DRINKING WATER	LEAD	12/30/23 @ 1000
034	77-B	DRINKING WATER	LEAD	12/30/23 @ 1000
035	78-A	DRINKING WATER	LEAD	12/30/23 @ 1000
036	78-B	DRINKING WATER	LEAD	12/30/23 @ 1000
037	79-A	DRINKING WATER	LEAD	12/30/23 @ 1000
038	79-B	DRINKING WATER	LEAD	12/30/23 @ 1000
039	80-A	DRINKING WATER	LEAD	12/30/23 @ 1000
040	80-B	DRINKING WATER	LEAD	12/30/23 @ 1000
041	81-A	DRINKING WATER	LEAD	12/30/23 @ 1000
042	81-B	DRINKING WATER	LEAD	12/30/23 @ 1000
043	82-A	DRINKING WATER	LEAD	12/30/23 @ 1000
044	82-B	DRINKING WATER	LEAD	12/30/23 @ 1000
045	83-A	DRINKING WATER	LEAD	12/30/23 @ 1000
046	83-B	DRINKING WATER	LEAD	12/30/23 @ 1000
047	84-A	DRINKING WATER	LEAD	12/30/23 @ 1000
048	84-B	DRINKING WATER	LEAD	12/30/23 @ 1000
049	85-A	DRINKING WATER	LEAD	12/30/23 @ 1000
050	85-B	DRINKING WATER	LEAD	12/30/23 @ 1000
051	86-A	DRINKING WATER	LEAD	12/30/23 @ 1000
052	86-B	DRINKING WATER	LEAD	12/30/23 @ 1000
053	87-A	DRINKING WATER	LEAD	12/30/23 @ 1000
054	87-B	DRINKING WATER	LEAD	12/30/23 @ 1000
055	88-A	DRINKING WATER	LEAD	12/30/23 @ 1000
056	88-B	DRINKING WATER	LEAD	12/30/23 @ 1000
057	89-A	DRINKING WATER	LEAD	12/30/23 @ 1000
058	89-B	DRINKING WATER	LEAD	12/30/23 @ 1000
059	90-A	DRINKING WATER	LEAD	12/30/23 @ 1000
060	90-B	DRINKING WATER	LEAD	12/30/23 @ 1000
061	91-A	DRINKING WATER	LEAD	12/30/23 @ 1000
062	91-B	DRINKING WATER	LEAD	12/30/23 @ 1000
063	92-A	DRINKING WATER	LEAD	12/30/23 @ 1000
064	92-B	DRINKING WATER	LEAD	12/30/23 @ 1000
065	93-A	DRINKING WATER	LEAD	12/30/23 @ 1000
066	93-B	DRINKING WATER	LEAD	12/30/23 @ 1000
067	94-A	DRINKING WATER	LEAD	12/30/23 @ 1000
068	94-B	DRINKING WATER	LEAD	12/30/23 @ 1000
069	95-A	DRINKING WATER	LEAD	12/30/23 @ 1000

14010257

24010252

010	95-B	DRINKING WATER	LEAD	12/30/23 @ 1000
011	96-A	DRINKING WATER	LEAD	12/30/23 @ 1000
012	96-B	DRINKING WATER	LEAD	12/30/23 @ 1000
013	97-A	DRINKING WATER	LEAD	12/30/23 @ 1000
014	97-B	DRINKING WATER	LEAD	12/30/23 @ 1000
015	98-A	DRINKING WATER	LEAD	12/30/23 @ 1000
016	98-B	DRINKING WATER	LEAD	12/30/23 @ 1000
017	99-A	DRINKING WATER	LEAD	12/30/23 @ 1000
018	99-B	DRINKING WATER	LEAD	12/30/23 @ 1000
019	100-A	DRINKING WATER	LEAD	12/30/23 @ 1000
020	100-B	DRINKING WATER	LEAD	12/30/23 @ 1000
021	101-A	DRINKING WATER	LEAD	12/30/23 @ 1000
022	101-B	DRINKING WATER	LEAD	12/30/23 @ 1000
023	102-A	DRINKING WATER	LEAD	12/30/23 @ 1000
024	102-B	DRINKING WATER	LEAD	12/30/23 @ 1000
025	103-A	DRINKING WATER	LEAD	12/30/23 @ 1000
026	103-B	DRINKING WATER	LEAD	12/30/23 @ 1000
027	104-A	DRINKING WATER	LEAD	12/30/23 @ 1000
028	104-B	DRINKING WATER	LEAD	12/30/23 @ 1000
029	105-A	DRINKING WATER	LEAD	12/30/23 @ 1000
030	105-B	DRINKING WATER	LEAD	12/30/23 @ 1000
031	106-A	DRINKING WATER	LEAD	12/30/23 @ 1000
032	106-B	DRINKING WATER	LEAD	12/30/23 @ 1000
033	107-A	DRINKING WATER	LEAD	12/30/23 @ 1000
034	107-B	DRINKING WATER	LEAD	12/30/23 @ 1000
035	108-A	DRINKING WATER	LEAD	12/30/23 @ 1000
036	108-B	DRINKING WATER	LEAD	12/30/23 @ 1000
037	109-A	DRINKING WATER	LEAD	12/30/23 @ 1000
038	109-B	DRINKING WATER	LEAD	12/30/23 @ 1000
039	110-A	DRINKING WATER	LEAD	12/30/23 @ 1000
040	110-B	DRINKING WATER	LEAD	12/30/23 @ 1000
041	111-A	DRINKING WATER	LEAD	12/30/23 @ 1000
042	111-B	DRINKING WATER	LEAD	12/30/23 @ 1000
043	112-A	DRINKING WATER	LEAD	12/30/23 @ 1000
044	112-B	DRINKING WATER	LEAD	12/30/23 @ 1000
045	113-A	DRINKING WATER	LEAD	12/30/23 @ 1000
046	113-B	DRINKING WATER	LEAD	12/30/23 @ 1000
047	114-A	DRINKING WATER	LEAD	12/30/23 @ 1000
048	114-B	DRINKING WATER	LEAD	12/30/23 @ 1000
049	115-A	DRINKING WATER	LEAD	12/30/23 @ 1000
050	115-B	DRINKING WATER	LEAD	12/30/23 @ 1000
051	116-A	DRINKING WATER	LEAD	12/30/23 @ 1000
052	116-B	DRINKING WATER	LEAD	12/30/23 @ 1000
053	117-A	DRINKING WATER	LEAD	12/30/23 @ 1000
054	117-B	DRINKING WATER	LEAD	12/30/23 @ 1000
055	118-A	DRINKING WATER	LEAD	12/30/23 @ 1000
056	118-B	DRINKING WATER	LEAD	12/30/23 @ 1000

24010252

057	119-A	DRINKING WATER	LEAD	12/30/23 @ 1000
058	119-B	DRINKING WATER	LEAD	12/30/23 @ 1000
059	120-A	DRINKING WATER	LEAD	12/30/23 @ 1000
060	120-B	DRINKING WATER	LEAD	12/30/23 @ 1000
061	121-A	DRINKING WATER	LEAD	12/30/23 @ 1000
062	121-B	DRINKING WATER	LEAD	12/30/23 @ 1000
063	122-A	DRINKING WATER	LEAD	12/30/23 @ 1000
064	122-B	DRINKING WATER	LEAD	12/30/23 @ 1000
065	123-A	DRINKING WATER	LEAD	12/30/23 @ 1000
066	123-B	DRINKING WATER	LEAD	12/30/23 @ 1000
067	124-A	DRINKING WATER	LEAD	12/30/23 @ 1000
068	124-B	DRINKING WATER	LEAD	12/30/23 @ 1000
069	125-A	DRINKING WATER	LEAD	12/30/23 @ 1000
070	125-B	DRINKING WATER	LEAD	12/30/23 @ 1000
071	126-A	DRINKING WATER	LEAD	12/30/23 @ 1000
072	126-B	DRINKING WATER	LEAD	12/30/23 @ 1000
073	127-A	DRINKING WATER	LEAD	12/30/23 @ 1000
074	127-B	DRINKING WATER	LEAD	12/30/23 @ 1000
075	128-A	DRINKING WATER	LEAD	12/30/23 @ 1000
076	128-B	DRINKING WATER	LEAD	12/30/23 @ 1000
077	129-A	DRINKING WATER	LEAD	12/30/23 @ 1000
078	129-B	DRINKING WATER	LEAD	12/30/23 @ 1000
079	130-A	DRINKING WATER	LEAD	12/30/23 @ 1000
080	130-B	DRINKING WATER	LEAD	12/30/23 @ 1000
081	131-A	DRINKING WATER	LEAD	12/30/23 @ 1000
082	131-B	DRINKING WATER	LEAD	12/30/23 @ 1000
083	132-A	DRINKING WATER	LEAD	12/30/23 @ 1000
084	132-B	DRINKING WATER	LEAD	12/30/23 @ 1000
085	133-A	DRINKING WATER	LEAD	12/30/23 @ 1000
086	133-B	DRINKING WATER	LEAD	12/30/23 @ 1000
087	134-A	DRINKING WATER	LEAD	12/30/23 @ 1000
088	134-B	DRINKING WATER	LEAD	12/30/23 @ 1000
089	135-A	DRINKING WATER	LEAD	12/30/23 @ 1000
090	135-B	DRINKING WATER	LEAD	12/30/23 @ 1000
091	136-A	DRINKING WATER	LEAD	12/30/23 @ 1000
092	136-B	DRINKING WATER	LEAD	12/30/23 @ 1000
093	137-A	DRINKING WATER	LEAD	12/30/23 @ 1000
094	137-B	DRINKING WATER	LEAD	12/30/23 @ 1000
095	138-A	DRINKING WATER	LEAD	12/30/23 @ 1000
096	138-B	DRINKING WATER	LEAD	12/30/23 @ 1000
097	139-A	DRINKING WATER	LEAD	12/30/23 @ 1000
098	139-B	DRINKING WATER	LEAD	12/30/23 @ 1000
099	140-A	DRINKING WATER	LEAD	12/30/23 @ 1000
100	140-B	DRINKING WATER	LEAD	12/30/23 @ 1000
101	141-A	DRINKING WATER	LEAD	12/30/23 @ 1000
102	141-B	DRINKING WATER	LEAD	12/30/23 @ 1000
103	142-A	DRINKING WATER	LEAD	12/30/23 @ 1000

24010253

044	142-B	DRINKING WATER	LEAD	12/30/23 @ 1000
045	143-A	DRINKING WATER	LEAD	12/30/23 @ 1000
046	143-B	DRINKING WATER	LEAD	12/30/23 @ 1000
047	144-A	DRINKING WATER	LEAD	12/30/23 @ 1000
048	144-B	DRINKING WATER	LEAD	12/30/23 @ 1000
049	145-A	DRINKING WATER	LEAD	12/30/23 @ 1000
050	145-B	DRINKING WATER	LEAD	12/30/23 @ 1000
051	146-A	DRINKING WATER	LEAD	12/30/23 @ 1000
052	146-B	DRINKING WATER	LEAD	12/30/23 @ 1000
053	147-A	DRINKING WATER	LEAD	12/30/23 @ 1000
054	147-B	DRINKING WATER	LEAD	12/30/23 @ 1000
055	148-A	DRINKING WATER	LEAD	12/30/23 @ 1000
056	148-B	DRINKING WATER	LEAD	12/30/23 @ 1000
057	149-A	DRINKING WATER	LEAD	12/30/23 @ 1000
058	149-B	DRINKING WATER	LEAD	12/30/23 @ 1000
059	150-A	DRINKING WATER	LEAD	12/30/23 @ 1000
060	150-B	DRINKING WATER	LEAD	12/30/23 @ 1000
4010254	151-A	DRINKING WATER	LEAD	12/30/23 @ 1000
061	151-B	DRINKING WATER	LEAD	12/30/23 @ 1000
062	152-A	DRINKING WATER	LEAD	12/30/23 @ 1000
063	152-B	DRINKING WATER	LEAD	12/30/23 @ 1000
064	153-A	DRINKING WATER	LEAD	12/30/23 @ 1000
065	153-B	DRINKING WATER	LEAD	12/30/23 @ 1000
066	154-A	DRINKING WATER	LEAD	12/30/23 @ 1000
067	154-B	DRINKING WATER	LEAD	12/30/23 @ 1000
068	155-A	DRINKING WATER	LEAD	12/30/23 @ 1000
069	155-B	DRINKING WATER	LEAD	12/30/23 @ 1000
070	156-A	DRINKING WATER	LEAD	12/30/23 @ 1000
071	156-B	DRINKING WATER	LEAD	12/30/23 @ 1000
072	157-A	DRINKING WATER	LEAD	12/30/23 @ 1000
073	157-B	DRINKING WATER	LEAD	12/30/23 @ 1000
074	158-A	DRINKING WATER	LEAD	12/30/23 @ 1000
075	158-B	DRINKING WATER	LEAD	12/30/23 @ 1000
076	159-A	DRINKING WATER	LEAD	12/30/23 @ 1000
077	159-B	DRINKING WATER	LEAD	12/30/23 @ 1000
078	160-A	DRINKING WATER	LEAD	12/30/23 @ 1000
079	160-B	DRINKING WATER	LEAD	12/30/23 @ 1000
080	161-A	DRINKING WATER	LEAD	12/30/23 @ 1000
081	161-B	DRINKING WATER	LEAD	12/30/23 @ 1000
082	162-A	DRINKING WATER	LEAD	12/30/23 @ 1000
083	162-B	DRINKING WATER	LEAD	12/30/23 @ 1000
084	163-A	DRINKING WATER	LEAD	12/30/23 @ 1000
085	163-B	DRINKING WATER	LEAD	12/30/23 @ 1000
086	164-A	DRINKING WATER	LEAD	12/30/23 @ 1000
087	164-B	DRINKING WATER	LEAD	12/30/23 @ 1000
088	165-A	DRINKING WATER	LEAD	12/30/23 @ 1000
089	165-B	DRINKING WATER	LEAD	12/30/23 @ 1000

24010254

031	166-A	DRINKING WATER	LEAD	12/30/23 @ 1000
032	166-B	DRINKING WATER	LEAD	12/30/23 @ 1000
033	167-A	DRINKING WATER	LEAD	12/30/23 @ 1000
034	167-B	DRINKING WATER	LEAD	12/30/23 @ 1000
035	168-A	DRINKING WATER	LEAD	12/30/23 @ 1000
036	168-B	DRINKING WATER	LEAD	12/30/23 @ 1000
037	169-A	DRINKING WATER	LEAD	12/30/23 @ 1000
038	169-B	DRINKING WATER	LEAD	12/30/23 @ 1000
039	170-A	DRINKING WATER	LEAD	12/30/23 @ 1000
040	170-B	DRINKING WATER	LEAD	12/30/23 @ 1000
041	171-A	DRINKING WATER	LEAD	12/30/23 @ 1000
042	171-B	DRINKING WATER	LEAD	12/30/23 @ 1000
043	172-A	DRINKING WATER	LEAD	12/30/23 @ 1000
044	172-B	DRINKING WATER	LEAD	12/30/23 @ 1000
045	173-A	DRINKING WATER	LEAD	12/30/23 @ 1000
046	173-B	DRINKING WATER	LEAD	12/30/23 @ 1000
047	174-A	DRINKING WATER	LEAD	12/30/23 @ 1000
048	174-B	DRINKING WATER	LEAD	12/30/23 @ 1000
049	175-A	DRINKING WATER	LEAD	12/30/23 @ 1000
050	175-B	DRINKING WATER	LEAD	12/30/23 @ 1000
051	176-A	DRINKING WATER	LEAD	12/30/23 @ 1000
052	176-B	DRINKING WATER	LEAD	12/30/23 @ 1000
053	ICE-1	DRINKING WATER	LEAD	12/30/23 @ 1000
054	ICE-2	DRINKING WATER	LEAD	12/30/23 @ 1000